Subject: Electrical Wiring, Power Board Reinstallation, and LAN Cable Concealment

Branch Name: Omkar Nagar
Branch Code: 123456
ATM ID: 123456789
Date of Visit: 2026-10-24
Location/Address: OMkar Nagar Nagpur
Technician Name: PRatik

1. Electrical Work Requirements

1. Ensure that no loose or exposed electrical power cables are visible inside the ATM area.
2. All electrical wiring conduits must be continuous and adequately protected against mechanical damage.
3. No electrical power points or sockets should be visible from inside the ATM room or ATM premises.
4. CAT 6 LAN cabling must be routed through a separate conduit from the electrical power wiring.
5. LAN cables and electrical power cables must not be routed together through the same conduit.

2. Site Coordination and Approval

6. The technician visiting the site must coordinate with Branch/ZO Officials to confirm the location for reinstalling the power board.
7. The power board must be reinstalled at the location approved by the concerned Branch/ZO Officials.
8. Geo-tagged photographs showing completed installation must be shared with Branch and ZO Officials.
9. The technician must obtain confirmation/approval from ZO Officials before leaving the site.

3. Final Inspection Checklist

No loose or exposed electrical cables are visible.	?
Electrical conduits are continuous and protected.	?
No power points or sockets are visible inside the ATM area.	?
CAT 6 LAN cable is routed through a separate conduit.	?
LAN and electrical power cables are not routed together through the same conduit.	?
Power board is reinstalled at the approved location.	?
Geo-tagged photographs of completed work are shared.	?
Approval/confirmation is received from ZO Officials.	?

Work Status: [X] Completed [ ] Pending [ ] Rectification Required

Remarks: asd

Technician Signature:

Branch Official Name & Signature:
Name: Pratik

Date and Time of Approval: 2026-10-26T13:01

Before Photo

Image not found or type unknown

After Photo

Image not found or type unknown